



Product Service

Attestation of Conformity

No. E8A 003649 0008 Rev. 01

Holder of Certificate: **Zhejiang CHINT Instrument & Meter Co., Ltd.**
 Wenzhou Bridge Industrial Zone
 325603 Yueqing
 PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Power meters
 (Smart Power Sensor)**

Model(s): **DTSU666-H, DTSU666-H 250A/50mA**

Description of Object: Rated voltage: 3*230/400 V
 Rated current: 100A/40mA (for DTSU666-H)
 250A/50mA (for DTSU666-H 250A/50mA)
 Protection class: II

Tested according to: EN 61326-1:2013
 EN 61326-2-1:2013

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 64713180045802

Date, 2019-05-10 (Tony Liu)

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE

A4 / 07.17